

ENGLISH VERSION OF THE OFFICIAL FRENCH PROCÈS-VERBAL N° EFR-20-002400A review 1

**Only the original French edition of this procès-verbal is authentic.
Seule l'édition originale en français du présent procès-verbal fait foi.**

The French PROCES VERBAL is valid for 5 years starting on July 23rd, 2020

This procès-verbal's translation cancels and replaces the procès-verbal's translation n°EFR-20-EPI-002400A

Applicant	SILENT GLISS FABRICS & COMPONENTS GmbH Rheinauenstrasse 8 79415 BAD BELLINGEN Allemagne
Sample reference	MULTISCREEN 1% MULTISCREEN 5% MULTISCREEN 10% TRISCREEN 1% TRISCREEN 3% TRISCREEN 5%
Brief description provided by the applicant	Fabric made of glass yarn and coated with in the mass fire-retarded PVC.
Mass per unit area determined by the laboratory	From 350 g/m ² ± 10% to 450 g/m ² ± 10%
Thickness measured by the laboratory	From 0,41 mm ± 10% to 0,55 mm ± 10%
Colour	All colors
End-use condition	Sun shade – Indoor application

Standard of tests:

- **NF P 92-507 (2004)** - Building - Interior fitting materials - Classification according to their reaction to fire
- **NF P 92-503 (1995)** - Reaction to fire tests - Electrical burner test used for flexible materials

Classification obtained in the official Procès Verbal:

M1

Valid for any application for which the product is not subjected to the CE marking.

Durability of the classification (NFP 92-512: 1986): Supposedly unlimited

Taking into account the criteria resulting from the tests described in the test report n°EFR-20-BE-002400 from July 24th, 2020.

This test report only demonstrates the characteristics of the test sample and does not prejudice the characteristics of similar products. It does not provide a certification of products within the Article L.115-27 of the Consumer Code and the Law of June 3rd, 1994.

Efectis France is approved for fire reaction tests according to the Decree of December 29th, 2016 amending the Decree of February 5th, 1959.

Les Avenières Veyrins-Thuellin, on February 11th, 2022